

**CLIENT:** Voss Solid GMBH  
In der Servine 3  
58239 Schwerte  
Germany

**Test Report No: RJ8877F-1**

**Date: February 15, 2023**

**SAMPLE ID:** The following test material was identified as: *Lynx Siding*.

**SAMPLING DETAIL:** Test Samples were submitted to the Laboratory directly by the client. No sampling or sample preparation were observed by QAI staff.

**DATE OF RECEIPT:** The samples were received at QAI Laboratories January 26, 2023.

**TESTING PERIOD:** February 07, 2023.

**AUTHORIZATION:** QAI Test Proposal 23MB01161R1 signed by Marcus Voss on January 20, 2023.

**TEST REQUESTED:** ASTM E136-19a "Standard Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace of 750°C".

**TEST RESULTS:** The tested material was considered to be non-combustible.


**CONCLUSION:** The submitted samples *has met* the classification as a non-combustible per testing to ASTM E136. See requirements on page 2.

**Prepared By**



Victor A Peinado  
Fire Lab Supervisor

**Signed for and on behalf of  
QAI Laboratories, Inc.**



Jason Friedrich P.E.  
Engineering Manager